## Fire Hydrant valve



### SPECIFICATION

- Body : Copper Alloy to BS1982
- Hand wheel : Grey Cast Iron to BS EN 1561
- Inlet : Flanged or BSP screw thread
- Outlet : Female instantaneousto BS 336 and other
- Working Pressure : connection
- Body Test Pressure : 15 Bar
- Code NO : DSR097-GM-65BSP

## Fire Globe valve 1.5"



### SPECIFICATION

- Working Pressure : 10 Bar
- Body Test Pressure : 16 Bar
- Body : BRASS
- Outlet Adaptor : Aluminium
- Materia : HRP336-BR-038-XX

## 2- WAY & 4- WAY BREECHING INLET



### SPECIFICATION

- Body : Ductile Iron
- Inlet : BS nstantaneous Male Copper Alloy to BS 1982
- Outlet : 2 Way Breeching Inlet Flanged 4" table E. BS 10
  2 Way Breeching Inlet Flanged 4" table E. BS 10
- Working Pressure : 10 Bar
- Testing Pressure : 20 Bar

| CODE No. | Description | Inlet Size | Onlet Size |
|---|---|---|---|
| DRS095-DI-BSPN16 | 2-way breeching inlet | BS 336 Male | Table E/PN 16 |
| WRS115-DI-BSPN16 | 4-way breeching inlet | BS 336 Male | Table E/PN 16 |

## FIRE DEPARTMENT CONNECTION



Material : Copper Alloy or Brass

| CODE No. | MIS271-GM-100-NA |
|---|---|

## UNDERGROUND HYDRANT BS 750



### SPECIFICATION

| | |
|---|---|
| BODY | Grey Cast Iron to BS 1561 |
| INLET | 445 mm x 280 mm |
| | Universal Flange PN16 & Table E |
| OUTLET | Copper Alloy to BS 1982 |
| TEST PRESSURE | 24 Bar |
| WORKING PRESSURE | 16 Bar |
| COLOUR | Black or Blue |
| CODE NO. | HYD058-CI-080-BK |

Head Office: 142 Central Axis - Fifth District- 6 of October
Ali El din Complex - Beside Leilet el Qadr - 6 of October
12 Nagib El-Rehany St, From El-Gomhoria st, Downtown
44 El-Atarin Mosque St, Alexandria
www.int-center.net

Tel: 0236860865 - 0236860864
Tel: 0238838732 - 0238838598
Tel: 01154002108
Tel: 01001297012
E-mail : info@int-center.net

UL LISTED FM APPROVED NFPA VdS LPCB